

LEGEND

Factory Low voltage Wiring

Factory Line Voltage Wiring

Field Low voltage Wiring

Field Line voltage Wiring

Printed Circuit Trace

Optional Wiring

Optional Block Capacitor

Circuit Breaker

Condensate Pan

Ground

High Pressure Switch

LED

Low Pressure Switch

Mate-N-Lock

Multi Splice Connector

\*

Optional

OVERLOAD

Relay contacts - N.C.

Relay contacts - N.O.

Relay / Contactor Coil

Solenoid Coil

Splice Cap

Temperature Switch

Thermistor

Wire Nut

AL Alarm Relay Contacts

BM Blower Motor

BMC Blower Motor Capacitor

BR Blower Relay

CAP Capacitor

CB Circuit Breaker

CC Compressor Contractor

CO Condensate Overflow Sensor

CR Compressor Relay

CTB Common Terminal Block

CS Current Sensor

DHW Domestic Hot Water

DM Damper Motor

DTS Discharge Temperature Switch

ES End Switch

EWTS Entering Water Temp Sensor

LT1 Sensor, low temp protection, water coil

LT2 Sensor, low temp protection, air coil

FSS Fan Speed Switch

HP High Pressure Switch

HPWS High Pressure Water Switch

HR Heating Relay

IAP Ionization Air Purifier

JV Jumper Wire

LAT Leaving Air Temperature

LP Low Pressure Switch

LOR Lock Out Relay

LWTS Leaving Water Temp Sensor

MOD Modulating Water Valve

MS Manual Starter

MSC Multi Splice Connector

MWV Motorized Water Valve

PB Power Terminal Block

PDB Power Distribution Block

POT Potentiometer

P1 Field Wiring Terminal Block

RAS Return Air Sensor

RVS Reversing Valve Solenoid

SAC Start Assist Capacitor

TB Terminal Block

TRANS Transformer

TS Terminal Strip

UMT Unit Mounted Thermostat

NOTES:

1. Compressor and Blower Motor thermally protected internally.

2. All wiring to the unit must comply with NEC and local codes  
low voltage wiring shall be Class 2 or equivalent.

3. Transformer wiring is voltage sensitive. Use layout corresponding to the unit voltage.

4. LT1 provides low temperature protection for WATER. When using ANTI-FREEZE solutions, cut JW3 jumper.

5. Typical heat pump thermostat wiring shown. Refer to thermostat IOM for wiring to the unit. T-Stat wiring must be "Class 1" and voltage rating equal to or greater than unit supply voltage.

6. 24V Alarm signal shown. For Dry Alarm contact between AL1 & AL2, cut JW1 for CXM/DXM Gen2 or JW4 DXM.

7. Transformer Secondary Ground via CXM/DXM board standoffs and screws to Control Box.

BM1. Fan motors factory wired for Medium Speed. For High or Low speed remove BLU wire from fan motor speed tap 'M' and connect to 'H' for High or 'L' for Low

MPC2. Refer to MPC Installation application, and Operation Manual For Control Wiring to the unit.

MPC3. ASW sensors are not required on Water-Water application. ASW06-ASW08 (Water-Air Only) move jumper to LSTAT, ASW13-ASW15 move jumper to Rnet.

