

☐ Wire

| | |
|-------|-----------------------------|
| P1 | Field Wiring Terminal Block |
| RAS | Return Air Sensor |
| RVS | Reversing Valve Solenoid |
| SAC | Start Assist Capacitor |
| TB | Terminal Block |
| TRANS | Transformer |
| TS | Terminal Strip |
| UMT | Unit Mounted Thermostat |

MPC2. Refer to MPC installation application, and Operation Manual For Control Wiring to the unit.

MPC3. ASW sensors are not required on Water-Water application. ASW06-ASW08 (Water-Air Only) move jumper to LSTAT, ASW09-ASW11 move jumper to Rnet.

MPC8. Factory cut JW1 jumper. Dry Contact will be available between AL1 and AL2

